






ELECTRICAL SYMBOLS

SYMBOL	DESCRIPTION
	CLOCK OUTLET ON 120V CIRCUIT. PROVIDE CLOCK AS MANUFACTURED BY PRIMEX WIRELESS, TRADITIONAL SERIES ANALOG, 12.5" MODEL #14306, WHITE.
	TEL/DATA DROP FOR SYSTEM FURNITURE. COORDINATE WITH OWNER FOR TERMINATIONS. THE NUMBER IN PARENTHESIS INDICATES THE NUMBER OF TEL/DATA CABLE DROPS.
	CEILING MOUNTED RECEPTACLE FOR WIRELESS ACCESS POINT, 2P, 3W, 20A, 125V, NEMA 5-20R.
	CEILING MOUNTED DATA OUTLET FOR WIRELESS ACCESS POINT.

Revision Number: 	Date of Revision: 03-16-07	Revision Description: ADDENDUM 2				Revision to Drawing: E001	
POTOMAC ENERGY GROUP INC. Consulting Engineers 20 South Quaker Lane Alexandria, Virginia 22314 Phone: 703-683-5000 Fax: 703-823-3358		Drawn:	Checked:	Scale:	Date: 03-16-07	Rec:	Sketch Number:
		Project Name: DULLES SOUTH MULTI-PURPOSE FACILITY					